

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3774-0399:121 Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** Alarm Lock Systems, 345 Bayview Ave., Amityville, NY 11701  
Contact: \*Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

**DESIGN:** Models DL2500, DL2500 LE, DL2700, DL2750 and DL3000 electrically controlled single point cylindrical lock sets with 1/2 in. latch bolts. The unit is furnished with a strike plate and intended for use with swinging type fire doors that have been properly sized and fitted to accommodate the lock set. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** DL2500, DL2500 LE: 9 VDC Alkaline Battery  
DL2700, DL2700 LE, DL3000: Five "AA" 7.5 VDC Alkaline Batteries

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation and UL label.

**APPROVAL:** Listed as electrically controlled locks for installation on swinging type fire doors where permitted per code. Maximum size up to 48" wide and 96" high. Authority having jurisdiction shall be consulted prior to installation.

\*Rev. 06-09-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager